

<b>ADDENDUM # 1</b>
---------------------

**CITY OF TORRANCE  
3031 Torrance Blvd.  
Torrance, CA 90503**

**BID NO. B2014-54**

---

**Bid for Lighting Retrofits**

---

ADDENDUM # 1- Issued 10/30/14

THE FOLLOWING CHANGES ARE HEREBY INCORPORATED INTO AND MADE A MANDATORY PART OF SUBJECT BID:

Bid Due Date Remains, **Wednesday, November 5, 2014 by 3:00 PM** in the City Clerk's office.

**CLARIFICATION**

- Contractor shall conduct an inventory of lights for accurate counts within 10 days after award
- Contractor shall properly dispose of all lights, ballasts, fixtures and associated materials in accordance with current State and Federal regulations
- The City may at its discretion retain ownership of one or more removed fixture(s). The City will notify the contractor of such fixtures, if any, 2 days prior to its scheduled removal. Such fixtures shall be removed without damage.

ATTACHMENT: As a courtesy the bid sheet is provided in a excel spreadsheet format. Included in the workbook are the following documents (see tabs at the bottom of spreadsheet).

- Bid sheet
- By type
- By facility

Questions asked during the bidding period and answers in **bold**.

1. Can you please let me know what the voltage is on the Sportlighters in Walteria Park?

**240 volt**